

Product specification

Dome Roof Extract

1.1. General

- A. Provide a roof mounted extract fan unit to meet the performance and configuration as indicated in the schedule and detail drawings. The unit shall be tested to BS EN ISO 5801:2017 and shall be of the Dome high performance fan type as manufactured by VES Andover Ltd a company accredited with BS EN ISO 9001:2008.

1.2. Unit Construction

- A. The cowl and base shall be manufactured using GRP and shall conform to BS 3532:1990 (type C) but if specific can be supplied to BS 3532:1990 (type E) having class II fire retardant characteristics in accordance with BS 476-7:1997.
- B. The roof unit fan shall be supplied with a 4-sided fan guard. Fan guards shall comply with safety guidelines established in BS EN ISO12499:2008.
- C. The supplied fan guards shall be manufactured from galvanised sheet steel to BS EN 10143:2006 and powder coated to match GRP.
- D. The unit colour will be in accordance with specification.
- E. The weatherproof unit is fitted with motor weather guard to prevent water ingress as manufactured by VES Andover Ltd.
- F. The base shall have an integrated raised inlet eye for the fan.
- G. The unit shall be supplied with four lifting lugs for safe handling and shall conform to safety standard BS EN 60950-1:2006. The lifting lugs shall be removable to enable removal once unit is in situ.

1.3. Impeller and motor

- A. The impeller and motor shall be selected to provide a low energy solution and conform to building regulations part L as well as being compliant with the ErP directives.
- B. The impellers shall be a high efficiency centrifugal backward curved design and shall be of a glass fibre reinforced plastic construction.
- C. The impeller shall be balanced in accordance with UNI ISO 1940-1:2003
- D. The motor shall have a die cast enclosure in aluminium alloy and shall be external rotor type with ball bearings.
- E. The motor shall be insulated to thermal class 155 (previously insulation class F).
- F. The motor shall have a protective finish.
- G. The motor shall be fitted with plug connection for ease of maintenance and shall be connected to a local isolator as standard.

1.4. Ancillaries

- A. The roof extract unit and ancillaries shall be of the Dome type as manufactured by VES Andover Ltd.

Download specification from www.ves.co.uk

Product Code Guide

Dome Roof Extract

Unit options

Product	Fan size	Phase	Motor	Unit protection	Controls	Colour
DME	133	-1	/EC	/BM	/I	/R7004
	315	-3				
	350					
	400					
	450					
	500					
	560					
	630					

Product

DME = Dome Extract

Motor

/EC = electronically commutated

Controls

/BM = bird mesh

Controls

/I = isolator

Controls

/R = RAL (colours)

Example codes

EC DME 315- 1/EC/BM/1